



STRUCTURES – DESIGN AND INSTALLATION REQUIREMENTS



TABLE OF CONTENTS

HANDHOLE – SECONDARY JUNCTION	RS-1
CLEARANCES TO WOOD POLES	RS-4
CLEARANCES TO EQUIPMENT PAD	RS-5
VEHICULAR PROTECTION BARRIERS	RS-6
CAPACITOR BANK PAD PLACEMENT (ADJACENT TO SIDEWALK)	
12kV	RS-7
25kV	RS-8
RESIDENTIAL TRANSFORMER PAD	
One Single-Phase Transformer, 12 or 25kV, Phase to Neutral	RS-13
Two Single-Phase Transformers, 12 or 25kV, Phase to Neutral	RS-14
SECONDARY METER PAD	RS-18
COMMERCIAL TRANSFORMER PAD	
One Single-Phase Transformer, 12 or 25kV	RS-19
Two Single-Phase Transformers, 12 or 25kV	RS-20
Three Single-Phase Transformers, 12 or 25kV	RS-21
RESIDENTIAL TRANSFORMER PAD (ONE 1Ø, 12KV PHASE TO PHASE).....	RS-28
THREE-PHASE TRANSFORMER PAD	
12 and 25kV, Single / Multi-Meter, 75 - 750KVA.....	RS-35
12 and 25kV, Single / Multi-Meter, 500 - 2500KVA.....	RS-37
12kV to 4kV Step Down.....	RS-40
25kV to 12kV Step Down.....	RS-41
FUSE CABINET PAD, 15KV.....	RS-45
FUSE / METER CABINET (15 AND 25KV) AND CAPACITOR BANK PAD (12KV).....	RS-46
CAPACITOR BANK CABINET PAD (25KV).....	RS-58
SERVICE PEDESTAL PAD (MOBILE HOME)	RS-70
SPLICE BOX (ID: 30" X 48" X 48")	RS-80

REV	REVISION RECORD	ENGR BY:	APPD BY:	DATE	 T&D STANDARDS NEVADA POWER COMPANY ELECTRIC SERVICE REQUIREMENTS				
5	RS – Structures Design & Installation Requirements Index				
4	.	.	.						
3	.	.	.						
2	.	.	.						
1	New Format	DH	MES	9/07	DI: ESRNPC-RSINX-REV01	SCALE: NONE	INITIAL ISSUE DATE: 09/05/2007	SHEET 1 OF 2	

STRUCTURES – DESIGN AND INSTALLATION REQUIREMENTS (CONTINUED)

REGULAR OR INTERCEPT BOX (ID: 36" X 72" X 48").....	RS-81
PULL BOX (ID: 36" X 84" X 48")	RS-82
INTERCEPT PULL BOX	
ID: 72" X 72" X 75".....	RS-83
ID: 30" X 48" X 48".....	RS-84
ID: 36" X 48" X 48".....	RS-85
MANHOLE (FEEDER CABLE SPLICE).....	RS-94
MANHOLE FOR S&F CABINET (12KV OR 25KV).....	RS-97
12KV MANHOLE PAD	
Adjacent to Public Right of Way	RS-98
Not Adjacent to Public Right of Way	RS-99
12KV MANHOLE AND CAPACITOR PAD	
Adjacent to Public Right of Way	RS-100
Not Adjacent to Public Right of Way	RS-101
25KV MANHOLE PAD	
Adjacent to Public Right of Way	RS-110
Not Adjacent to Public Right of Way	RS-111
25KV MANHOLE AND CAPACITOR PAD	
Adjacent to Public Right of Way	RS-112
Not Adjacent to Public Right of Way	RS-113
MANHOLE PAD FOR SWITCH, FUSE, AND METER CABINET	RS-116

		T&D STANDARDS NEVADA POWER COMPANY ELECTRIC SERVICE REQUIREMENTS
RS – Structures Design & Installation Requirements Index		
DI: ESRNPC-RSINX-REV01	SHEET 2 OF 2	
SCALE: NONE	INITIAL ISSUE DATE: 09/05/2007	